

# SoC Over Time: P.S. Optimizer vs. Standard Controls on a 1MW/1MWh System



	PS Optimizer	Standard Method
Performance Score	0.944490979	0.940094442
DoD	24.58889986	59.62265793
Average SoC	49.6251217	47.46874928
STD SoC	4.696884941	9.197101755
Max. SoC	62.98835494	76.34818966
Min. SoC	38.39945508	16.72553173
Cycles	6.705067287	7.013575463